

## Part L Specification

**BER IS NOT PUBLISHED**

### Property Details

Dwelling Type	Detached house	Type of BER rating	New Dwelling - Provisional
Address line 1	1 Main Street	Year of Construction	2021
Address line 2		Date of Assessment	19/04/2021
Address line 3	Town	Date of Plans	
County	Co. Kildare	Planning Reference	
Eircode		Building Regulations	2019 TGD L
BER Number		MPRN No.	0
Purpose of Rating	New dwelling for owner occupation	Is MPRN shared with another dwelling?	N/A
Assessor Name		BER number assigned to shared dwelling	N/A
Comment			

### Dimension Details

	Area [m <sup>2</sup> ]	Height [m]	Volume [m <sup>3</sup> ]	
Ground Floor	165.00	2.50	412.50	
First Floor	0.00	0.00	0.00	
Second Floor	0.00	0.00	0.00	
Third and other floors	0.00	0.00	0.00	
Room in roof	0.00	0.00	0.00	
Total Floor Area	165.00		412.50	
Living Area [m <sup>2</sup> ]	96.00			Living area percentage [%] 58.18
No of Storeys	1			

### Ventilation Details

	Number		
Chimneys	0	Has permeability test been carried out?	Yes
Open Flues	0	Structure type	N/A
Fans & Vents	0	Is there a suspended wooden ground floor?	No
Number of flueless combustion room heaters	0	Percentage windows/doors draught stripped [%]	N/A
Is there a draught lobby on main entrance?	No	Number of sides sheltered	1
Ventilation method	Balanced whole-house mechanical ventilation with heat recovery	Mechanical Ventilation Manufacturer	MHRV System
Specific fan power [W/(L/s)]	0.600	Mechanical Ventilation Model Name	XYZ1
Heat exchanger efficiency [%]	95.00	How many wetrooms (incl. kitchen)?	2+k

### Building Elements - Floor Details

Type	Description	Underfloor heating	U-Value [W/m <sup>2</sup> K]	Area [m <sup>2</sup> ]
	Ground Floor - Solid	No	0.094	165

### Building Elements - Roof Details

Type	Description	U-Value [W/m <sup>2</sup> K]	Area [m <sup>2</sup> ]
	Pitched Roof - Insulated on Rafter	0.09	165

### Building Elements - Wall Details

Type	Description	U-Value [W/m <sup>2</sup> K]	Area [m <sup>2</sup> ]
	Other	0.131	155

### Building Elements - Door Details

Description	Number of Doors	U-Value [W/m <sup>2</sup> K]	Area [m <sup>2</sup> ]
	1	1.2	2.030
	1	1.4	2.480

DRAFT

## Building Elements - Window Details

Glazing type	User defined u-value	U-Value [W/m <sup>2</sup> K]	Area [m <sup>2</sup> ]
Double-glazed, argon filled (low-E, en = 0.05, soft coat)	Yes	1.000	17.870
Double-glazed, argon filled (low-E, en = 0.05, soft coat)	Yes	1.000	7.470
Double-glazed, argon filled (low-E, en = 0.05, soft coat)	Yes	1.000	13.530
Double-glazed, argon filled (low-E, en = 0.05, soft coat)	Yes	1.000	1.690

DRAFT

## Other Details

Thermal bridging factor [W/m <sup>2</sup> k]	0.0800	Thermal mass category of dwelling	Medium
--	--------	-----------------------------------	--------

### Heating System - Solar Water Heating

Solar Water Heating Present?	Yes	Aperture area of solar collector [m <sup>2</sup> ]	6.000
Type, manufacturer, model	Evacuated tube, Photonomi Global Group a.r.l., 501 4		
Zero loss collector efficiency, n0	0.750	Collector heat loss coefficient, a1 [W/m <sup>2</sup> >K]	2.368
Annual Solar Radiation [kWh/m <sup>2</sup> ] (Refer to Appendix H in DEAP)	1074	Overshading factor	1
Dedicated storage volume [Litres]	150	Combined Cylinder	Yes
Solar fraction [%]	60.984		

### Heating System - Hot Water System

Distribution Losses	395.69	Combi boiler present?	No
Supplementary electric water heating	N/A	Water Storage Volume [L]	300
Hot water storage manufacturer and model name	HONE	Declared loss factor [kWh/d]	1.92
Temperature factor unadjusted	0.6	Temperature Factor Multiplier	0.9
Primary Circuit loss type	Boiler with insulated primary pipework and with cylinder thermostat		
Is hot water storage indoors or in group heating system?	Yes	Insulation type	None
Insulation thickness [mm]	0		

### Heating System - Dist. system losses and gains

Temperature adjustment [°C]	0	Control Category	3	Responsiveness category	1
Central heating pumps	1	Oil Boiler Pump	1	Oil boiler pump inside dwelling	No
Gas boiler flue fan	0	Warm air heating or fan coil radiators present	No		

### Heating System - Energy Requirements (Individual)

Main space heating system efficiency [%]	94.9	Space heating efficiency adjustment factor	1.0000	Main space heating fuel	Heating Oil
Main water heating system efficiency [%]	94.9	Water heating efficiency adjustment factor	1.0000	Main water heating fuel	Heating Oil
Secondary heating system efficiency [%]	N/A	Fraction of heating from secondary heating system	N/A	Secondary space heating system fuel	None
Fraction of main space and water heat from CHP	N/A	Electrical efficiency of CHP	N/A	Heat efficiency of CHP	N/A
CHP Fuel type	N/A				

### Summary for Part L Conformance (Applies to TGD L 2008/2011/2019 for new dwellings only)

BER Number		Building Regulations	2019 TGD L
BER Result	A1	Energy Value kWh/m <sup>2</sup> /yr	-2.46
CO <sub>2</sub> emissions [kg/m <sup>2</sup> /yr]	1.41		
EPC	-0.014	EPC Pass/Fail	Pass
CPC	0.037	CPC Pass/Fail	Pass

### Part L Conformance - Fabric

Conformity with Maximum avg U-value requirements	U-value [W/m <sup>2</sup> K]	Pass/Fail	Conformity with Maximum U-value requirements	U-Value [W/m <sup>2</sup> K]	Pass/Fail
Pitched roof insulated on ceiling	0.00	Pass	Roofs	0.09	Pass
Pitched roof insulated on slope	0.09	Pass	Walls	0.131	Pass
Flat Roof	0	Pass	Floors	0.094	Pass
Floors with no underfloor heat	0.09	Pass	External doors / windows / rooflights	1.40	Pass
Floors with underfloor heat	0.00	Pass			
Walls	0.13	Pass			
Percentage of opening areas [%]	27.32				
Average U value of openings	1.03	Pass			
Permeability test carried out and meets guidelines in TGD L				0.15	Pass

Part L Conformance - Renewables (applies to TGD L 2019)

	Source	Renewables Primary Energy	Total Primary Energy	RER
+ Delivered energy	PV/Wind	8292.13	8292.13	
+ Delivered energy	Other	0.00	0.00	
+ Delivered energy	Solar	1608.70	1608.70	
+ Delivered energy	Biomass	0.00	0.00	
+ Delivered energy	Biodiesel	0.00	0.00	
+ Delivered energy	Bioethanol	0.00	0.00	
+ Environmental energy	HP	0.00	0.00	
+ Saved energy	CHP	0.00	0.00	
+ District heating	District Heating	0.00	0.00	
+ Delivered energy	Grid	0.00	-6573.43	
+ Delivered energy	Thermal	0.00	6167.72	
<b>SUBTOTAL</b>		<b>9900.83</b>	<b>9495.13</b>	<b>1.04 - Pass</b>
Energy not used in Regulated Loads	PV/Wind/CHP	0.00	-6573.43	
<b>TOTAL</b>		<b>9900.83</b>	<b>16068.56</b>	<b>0.62</b>

**DRAFT**